

Sevier_2337



Date Issued: 8-28-06 Revision Date: Jan. 05

Compressive Strength of Concrete Cylinder Test Specimens
ASTM C39 / C143 / C239 / C1064

ASTM C39 / C143 / C239 / C1064

Jones & DeMille Engineering
1535 South 100 West
Richfield, UTAH 84701
Phone: (435) 896-8200 Fax: (435) 896-8208

Project: Pahvant Elementary AdditionConcrete Supplier: Halles Sand & Gravel

Project Number: 0602-030

Client: School Dist.Cement Source: AshgroveType: IIIVAggregate Source: Hales

Sand Source: Hales

Max ID Number:

Air Entraining:

Bag Max 6.5

Truck & Trailer No.:

Concrete Temp. (F): 79 FAir Temp (F) 79 FSize of Cylinders 4 X 8# Cylinders Cast: 4

Aggregate Size:

Yards Belched:




Air Correlation Factor:

Correlation:

Stump: 5"Alt: 0.2

Cast By: Tom L

With Fiber

[illegible]Cylinders Broken By: Daniel HarveyComments: Set #3 Load #10

Lab Supervisor:

Construction Inspection Summary Report
Sevier School District
 (For all projects exceeding \$100,000)

Inspections for Month of: <u>May</u>		Year: <u>2006</u>	USOE Project Number:
Job Name/Description: <u>Pahvant Elementary Addition</u>		Address: <u>Richfield, Utah</u>	Form Completed by: <u>John L. Hicks</u>
		2006	Title: <u>Bldg. official</u>
General Contractor: <u>Valley Builders Inc., Gunnison, Utah</u>			
Total Number of Inspections for Period:			
Building/Architectural		Structural	
<input type="checkbox"/> Fireproof	Notes	<input type="checkbox"/> Footings	Notes
<input type="checkbox"/> Waterproof		<input type="checkbox"/> Formwork	
<input type="checkbox"/> Underground		<input type="checkbox"/> Foundation	
<input type="checkbox"/> Drywall/Paint		<input type="checkbox"/> Rebar	
<input type="checkbox"/> Roofing		<input type="checkbox"/> Framing	
<input type="checkbox"/> Compaction		<input type="checkbox"/> Columns	
<input type="checkbox"/> Final Grade		<input type="checkbox"/> Steel	
<input type="checkbox"/> Accessibility		<input checked="" type="checkbox"/> Masonry	
<input type="checkbox"/>		<input type="checkbox"/> Decking	
<input type="checkbox"/>		<input type="checkbox"/> Bolts/Welds	
Mechanical		Plumbing	
<input type="checkbox"/> Rough--Above Ground	Notes	<input type="checkbox"/> Rough Underground	Notes
<input type="checkbox"/> Rough--Under Ground		<input type="checkbox"/> Underground Gas	
<input type="checkbox"/> Ductwork		<input type="checkbox"/> Above Rough	
<input type="checkbox"/> Insulation		<input type="checkbox"/> Sewer	
<input type="checkbox"/> Air Tests		<input type="checkbox"/> Culinary	
<input type="checkbox"/> Equipment		<input type="checkbox"/> Roof Drain	
<input type="checkbox"/> Refrigeration		<input type="checkbox"/> Testing	
<input type="checkbox"/> Controls		<input type="checkbox"/> Finish	
<input type="checkbox"/> Hydronic Test		<input type="checkbox"/> Fire Sprinkler--Rough	
<input type="checkbox"/>		<input type="checkbox"/> Fire Sprinkler--Finish	
Electrical		Other/Special	
<input type="checkbox"/> Rough Underground	Notes	<input type="checkbox"/> Boiler	Notes
<input type="checkbox"/> Finish Electrical		<input type="checkbox"/> Pressure Vessels	
<input type="checkbox"/> Fire Alarm		<input type="checkbox"/> Elevators	
<input type="checkbox"/> Sound		<input type="checkbox"/>	
<input type="checkbox"/> Computer Cable		<input type="checkbox"/>	
<input type="checkbox"/> Telephone Cable		<input type="checkbox"/>	
<input type="checkbox"/> Security/Energy		<input type="checkbox"/>	
<input type="checkbox"/> Rough Above Ground		<input type="checkbox"/>	
<input type="checkbox"/> Power Service		<input type="checkbox"/>	
<input type="checkbox"/>		<input type="checkbox"/>	

Building Official Signature: John L. HicksDate: 5/10/06

Please e-mail this form to Jane Z. Zhang: jane.zhang@schools.utah.gov.

Construction Inspection Summary Report Sevier School District

(For all projects exceeding \$100,000)

Inspections for Month of: <u>June</u>		Year: <u>2006</u>	USOE Project Number:
Job Name/Description:		Address:	Form Completed by:
Pahvant Elementary Addition		Richfield, Utah	2006
			Title: <u>John L. Hicks</u> <u>Bldg. official</u>
General Contractor: Valley Builders Inc., Gunnison, Utah			
Total Number of Inspections for Period:			
Building/Architectural		Notes	Structural
[]	Fireproof		[]
[]	Waterproof		[]
[]	Underground		[]
[]	Drywall/Paint		[]
[]	Roofing		[]
[]	Compaction		[]
[]	Final Grade		[]
[]	Accessibility		[]
[]			[]
[]			[]
[]			[]
[]			[]
Mechanical		Notes	Plumbing
[]	Rough--Above Ground		[]
[]	Rough--Under Ground		[]
[]	Ductwork		[]
[]	Insulation		[]
[]	Air Tests		[]
[]	Equipment		[]
[]	Refrigeration		[]
[]	Controls		[]
[]	Hydronic Test		[]
[]			[]
[]			[]
[]			[]
Electrical		Notes	Other/Special
[]	Rough Underground		[]
[]	Finish Electrical		[]
[]	Fire Alarm		[]
[]	Sound		[]
[]	Computer Cable		[]
[]	Telephone Cable		[]
[]	Security/Energy		[]
[]	Rough Above Ground		[]
[]	Power Service		[]

Building Official Signature:

Date:

Please e-mail this form to Jane Z. Zhang: jane.zhang@schools.utah.gov.

Called UPTL 1/14/06
Left Message

() County () Aurora 250 NORTH MAIN STREET
() Richfield () Annabella RICHFIELD, UTAH 84701
(X) Salina () Central Valley 893-0420
() Monroe () Elsinore
() **** Inspection Report ****

- () Glenwood
- () Joseph
- () Koosharem
- () Venice
- () Sigurd

Contractor 4-D's
 Property Owner Salina Elementary Date 7/14/2006
 Property Address 210 West 300 North Time 1:15
 Subdivision Name _____ Lot # _____ A.M. () P.M. (☒)
 Reason for: Called (☒) Routine () Complaint () Special ()

INSPECTION KIND: Power

Bldg. () **Elec. (X)** **Plbg. ()** **Mech. ()** **Zoning ()** **Housing ()**

Residential () **Commercial (X)** **Reinspection ()**

STAGE: _____

Partial () Completed () Work Approved () Work in Violation ()

TYPE OF INSPECTION: _____

Footings ()	Underground Plbg. ()	Bond Beam ()	Foundation ()
Sign ()	Fire ()	Intermediate ()	Electrical Tag (X)
Insulation ()	Framing ()	Shear Panel ()	Progress ()
Sheet Rock ()	Plumbing Test ()	Final ()	Other ()

COMMENTS: UP&L # 242108

Building passes inspection above (✓)
Reinspection Required ()

Signed: _____ Sevier County Building Inspector

Sevier_2337

SEVIER COUNTY BUILDING INSPECTION DEPARTMENT
250 NORTH MAIN STREET
RICHFIELD, UTAH 87401
893-0420

*****CONDITIONAL USE PERMIT*****

Applicant: Pahvant Elementary

Project Address: 240 West 500 North, Richfield, Utah 84701

Date: August 21, 2006

This conditional use permit gives you permission to occupy the Pahvant Elementary School addition under the conditions that you will schedule a final re-inspection on the following items:

1. Handrails and guardrails in the mezzanine
2. Thresholds and weather stripping on classroom doors
3. Install handrails and guardrails on steps and ramps
4. Rooms 189 and 191 not finished-but unoccupied
5. Caulk around drinking fountains
6. Caulk around all sinks, toilets and urinals
7. Run water to restrooms so tests on toilets can be made
8. Install smoke detectors in restrooms. Finish lights and hang door on storage room off from south restroom.
9. Install fire extinguishers and fire doors
10. Finish all plumbing and electrical
11. Install glass in all classroom doors
12. Install locks and openers on all doors
13. Intercom must be operating
14. Need handicap and parking stripes

You will have ten days from today's date to schedule the inspection. **August 30, 2006.**

This is a legal and binding agreement between the Sevier County Building Department and property owner (Contractor).



Property owners signature

8-28-06
Date



Sevier County Building Official signature

8-29-06
Date

Certificate of Occupancy
County of Sevier
Department of Building Inspection

This Certificate issued pursuant to the requirements of Section 306 of the Uniform Building Code certifying that at the time of issuance this structure was in compliance with the various ordinances of the City regulating construction or use. For the following:

Group E Type of Construction V

Owner of Building Pahvant Elementary Address 240 West 500 North

Building Address 240 West 500 North Locality Richfield, Utah 84701

By: Sevier County Building Dept.

John L. Hicks- John L. Hicks Date: August 31, 2006

Building Official

POST IN A CONSPICUOUS PLACE

**CERTIFICATE OF FIRE CLEARANCE
FOR**

Pavhant Elementry School

**THIS CERTIFIES THAT A REASONABLE DEGREE OF LIFE SAFETY EXISTS
TO PERMIT OCCUPANCY OF THIS STRUCTURE.**

**THIS CERTIFICATE IS ISSUED SUBJECT TO THE SUCCESSFUL COMPLETION OF A FINAL
INSPECTION, AND PERTAINS TO THE TYPE OF OCCUPANCY AND BUILDING CONFIGURATION
EXISTING AS OF August 31, 2006**

**ANY MODIFICATION TO THIS STRUCTURE, AFFECTING LIFE SAFETY, WITHOUT THE PRIOR
CONSENT OF THE OFFICE OF THE STATE FIRE MARSHAL, SHALL VOID THIS CERTIFICATE.**

Signature Troy D. Smith
Deputy State Fire Marshal

THIS CERTIFICATE SHALL BE KEPT ON FILE AND AVAILABLE FOR REVIEW UPON REQUEST.

**CERTIFICATE OF FIRE CLEARANCE
FOR**

Pavhant Elementry School

**THIS CERTIFIES THAT A REASONABLE DEGREE OF LIFE SAFETY EXISTS
TO PERMIT OCCUPANCY OF THIS STRUCTURE.**

**THIS CERTIFICATE IS ISSUED SUBJECT TO THE SUCCESSFUL COMPLETION OF A FINAL
INSPECTION, AND PERTAINS TO THE TYPE OF OCCUPANCY AND BUILDING CONFIGURATION
EXISTING AS OF August 31, 2006**

**ANY MODIFICATION TO THIS STRUCTURE, AFFECTING LIFE SAFETY, WITHOUT THE PRIOR
CONSENT OF THE OFFICE OF THE STATE FIRE MARSHAL, SHALL VOID THIS CERTIFICATE.**

Signature Troy D. Smith
Deputy State Fire Marshal

THIS CERTIFICATE SHALL BE KEPT ON FILE AND AVAILABLE FOR REVIEW UPON REQUEST.

Certificate of Occupancy
County of Sevier
Department of Building Inspection

This Certificate issued pursuant to the requirements of Section 306 of the Uniform Building Code certifying that at the time of issuance this structure was in compliance with the various ordinances of the City regulating construction or use. For the following:

Group E Type of Construction V

Owner of Building Pahvant Elementary Address 240 West 500 North

Building Address 240 West 500 North Locality Richfield, Utah 84701

By: Sevier County Building Dept.

John L. Hicks- John L. Hicks Date: August 31, 2006

Building Official

POST IN A CONSPICUOUS PLACE

Sevier_2337

SEVIER COUNTY BUILDING INSPECTION DEPARTMENT
250 NORTH MAIN STREET
RICHFIELD, UTAH 87401
893-0420

*****CONDITIONAL USE PERMIT*****

Applicant: Pahvant Elementary

Project Address: 240 West 500 North, Richfield, Utah 84701

Date: August 21, 2006

This conditional use permit gives you permission to occupy the Pahvant Elementary School addition under the conditions that you will schedule a final re-inspection on the following items:

1. Handrails and guardrails in the mezzanine
2. Thresholds and weather stripping on classroom doors
3. Install handrails and guardrails on steps and ramps
4. Rooms 189 and 191 not finished-but unoccupied
5. Caulk around drinking fountains
6. Caulk around all sinks, toilets and urinals
7. Run water to restrooms so tests on toilets can be made
8. Install smoke detectors in restrooms. Finish lights and hang door on storage room off from south restroom.
9. Install fire extinguishers and fire doors
10. Finish all plumbing and electrical
11. Install glass in all classroom doors
12. Install locks and openers on all doors
13. Intercom must be operating
14. Need handicap and parking stripes

You will have ten days from today's date to schedule the inspection. **August 30, 2006.**

This is a legal and binding agreement between the Sevier County Building Department and property owner (Contractor).



Property owners signature

8-28-06
Date



Sevier County Building Official signature

8-29-06
Date

**CERTIFICATE OF FIRE CLEARANCE
FOR**

Pavhant Elementry School

**THIS CERTIFIES THAT A REASONABLE DEGREE OF LIFE SAFETY EXISTS
TO PERMIT OCCUPANCY OF THIS STRUCTURE.**

**THIS CERTIFICATE IS ISSUED SUBJECT TO THE SUCCESSFUL COMPLETION OF A FINAL
INSPECTION, AND PERTAINS TO THE TYPE OF OCCUPANCY AND BUILDING CONFIGURATION
EXISTING AS OF August 31, 2006**

**ANY MODIFICATION TO THIS STRUCTURE, AFFECTING LIFE SAFETY, WITHOUT THE PRIOR
CONSENT OF THE OFFICE OF THE STATE FIRE MARSHAL, SHALL VOID THIS CERTIFICATE.**

Signature Troy D. Smith
Deputy State Fire Marshal

THIS CERTIFICATE SHALL BE KEPT ON FILE AND AVAILABLE FOR REVIEW UPON REQUEST.

Called UPTL 1/14/06
Left Message

() County () Aurora 250 NORTH MAIN STREET
() Richfield () Annabella RICHFIELD, UTAH 84701
(X) Salina () Central Valley 893-0420
() Monroe () Elsinore
() **** Inspection Report ****

- () Glenwood
- () Joseph
- () Koosharem
- () Venice
- () Sigurd

Contractor 4-D's
 Property Owner Salina Elementary Date 7/14/2006
 Property Address 210 West 300 North Time 1:15
 Subdivision Name _____ Lot # _____ A.M. () P.M. (☒)
 Reason for: ☒ Called (X) ☐ Routine () ☐ Complaint () ☐ Special ()

INSPECTION KIND: Power

Bldg. () **Elec. (X)** **Plbg. ()** **Mech. ()** **Zoning ()** **Housing ()**

Residential () **Commercial (X)** **Reinspection ()**

STAGE: _____

Partial () Completed () Work Approved () Work in Violation ()

TYPE OF INSPECTION: _____

Footings ()	Underground Plbg. ()	Bond Beam ()	Foundation ()
Sign ()	Fire ()	Intermediate ()	Electrical Tag (X)
Insulation ()	Framing ()	Shear Panel ()	Progress ()
Sheet Rock ()	Plumbing Test ()	Final ()	Other ()

COMMENTS: UP&L # 242108

Building passes inspection above (✓)
Reinspection Required ()

Signed: _____ Sevier County Building Inspector

SEVIER COUNTY BUILDING DEPARTMENT

() County () Aurora **250 NORTH MAIN STREET**
(x) Richfield () Annabella **RICHFIELD, UTAH 84701**
() Salina () Central Valley **893-0420**
() Monroe () Elsinore
() _____ **** Inspection Report ****

- () Glenwood
- () Joseph
- () Koosharem
- () Venice
- () Sigurd

Contractor Ken Thomas
 Property Owner Pahvant Elementary Date 4/27/2006
 Property Address 240 West 500 North Time _____
 Subdivision Name _____ Lot # _____ A.M. () P.M. ()
 Reason for: Called (✓) Routine () Complaint () Special ()

INSPECTION KIND: Addition

Bldg. () Elec. () Plbg. () Mech. () Zoning () Housing ()
Residential () Commercial (X) Reinspection ()

STAGE:

Partial () Completed () Work Approved () Work in Violation ()

TYPE OF INSPECTION: Masonry

Footings ()	Underground Plbg. ()	Bond Beam ()	Foundation ()
Sign ()	Fire ()	Intermediate ()	Electrical Tag ()
Steel ()			
Insulation ()	Framing ()	Shear Panel ()	Progress ()
Sheet Rock ()	Plumbing Test ()	Final ()	Other ()

COMMENTS:

Building passes inspection above (12)

Reinspection Required ()

Signed:

Sevier County Building Inspector

Sevier_2337

FAX TRANSMISSION

JONES & DEMILLE ENGINEERING
1535 SOUTH 100 WEST
RICHFIELD, UT 84701
(435) 896-8266
FAX: (435) 896-8268

To:	Hales Sand & Gravel	Date:	8/29/06
		Fax #:	527-3560
Project:	Pahvant Elementary Addition	Project #:	0602-060
From:	Ked Nielsen	Pages:	10
Subject:	Materials Testing		

Comments:

cc: Sevier School District, 896-8804

*Print -
Scan & E-mail*



Date Issued:

B-28-06

Revision Date: Jan. 05

Compressive Strength of Concrete Cylindrical Test Specimens
ASTM C39 / C143 / C239 / C1064

ASTM C39 / C143 / C239 / C1064

Jones & DeMille Engineering

1535 South 100 West

Richfield, UTAH 84701

Phone: (435) 696-2266 Fax: (435) 593-8269

Project: Parvart Elementary Addition

Concrete Supplier: Hales Sand & Gravel

Project Number: 0802-060Client School Dist.Cement Source: AshtgroveType: INAggregate Source: HalesSand Source: Hales

MEX ID Number:

All-Entraining

Bag Mix:

Truck & Tractor No.

Concrete Temp. (F):

Air Temp (F) 71 F

Size of Cylinders

Cylinders Cast: 4

Aggregate Size

Yards Batched

Air Correlation Factor

Correlation

ជំពូកទី៨

Alt: _____ b

Call By:

1000 L

[illegible]Cylinders Broken By: Daniel Hawley

Comments:

Lab Supervisor

DATE: 11/11/2011
NAME: David Hawkey



Date Issued: 8-28-06 Revision Date: Jan. 05

Compressive Strength of Concrete Cylinder Test Specimens

ASTM C39 / C143 / C239 / C1D64

Jones & DeFalle Engineering
1535 South 100 West
Richtfield, UT 84701
Phone: (435) 998-8200 Fax: (435) 995-8200

Project: Pahvant Elementary Addition

Concrete Supplier: Hales Sand & Gravel

Project Number: 0502-060

Client: School Dist.

Cement Source: AshgroveType: IV

Aggregate Source:

Sand Source: Hales

Mtx ID Number:

Air Entrapping:

Bag Mix 6.5

Truck & Ticket No.:

Concrete Temp. (F): 78 FAir Temp (F) 59 FSize of Cylinders 4 x 8# Cylinders Cast: 4

Aggregate Size:

Yarcs Batched:

Air Correlation Factor:

Correlations:

Slump: 4"


Alt: _____

Cast By: 1001 L


With Fiber




Com
(2)




Cone and
(b)



(a) **Shen**



(d)



(e)

[illegible]

Cylinders Broken By: Daniel Hawley

Lab Supervisor:

Comments: Set #1 Load #1

Hea R. V. Jellie



Dele besværet

8-28-06

Revision Date: Jan. 05

Compressive Strength of Concrete Cylinder Test Specimens

ASTM C39 / C143 / C239 / C1064

Jones & DeMille Engineering
1535 South 100 West
Richfield, UTAH 84701
Phone: (435) 888-5206 Fax: (435) 856-8709

Project: Pahvant Elementary Addition

Concrete Supplier: Hales Sand & Gravel

Project Number: 0502-080

Client: School Dist.Cement Source: AshgroveType: INAggregate Source: HalesSand Source: Hales

Milk ID Number: _____

Air Entraining:

Bag Mix 6.5

Truck & Ticket No.:

Concrete Temp. (F): 73FAir Temp (F) 69 FSize of Cylinders 4 x 8# Cylinders Cast: 4

Aggregate Size: 3/4"

Yards Batched:





Air Correlation Factor:

Correlation:

Slump: 5-1/2"Alr: 8.4

Cast By: Tom L.

Wash Fiber

[illegible]

Cylindars Broken By: Daniel Hawley

Lab Supervisor:

Comments: Set #2 Load #5

Sevier_2337

Sevier_2337



Date Issued: **ES-26-06** Revision Date: Jun. 05

Compressive Strength of Concrete Cylinder Test Specimens

Jones & DeMille Engineering
1535 South 100 West
Richfield, UTAH 84701
Phone: (435)396-6705; Fax: (435)368-8269

Project: Pehvant Elementary Addition

Project Number: 0502-060

Aggregate Source: Hales

Mix ID Number: _____

Bag Mix 8.5Concrete Temp. (F): 79 F

Size of Cylinders 4 x 8

Aggregate Size: 3/4"

Air Correlation Factor: _____

Slump: 3-1/2"

Client: School Dist

Sand Source: Hales

Air Entraining: _____

Check & Ticket No.: _____

Air Temp (F) 72 FCylinders Cast: 4

Yards Batched: _____

Correlation: _____

Alr: 5.8

Cast By: Tom L

Tom L

!

(b) Cora

Conc

11

6

1


雷

[illegible]Cylinders Broken By: Daniel Hawley

Comments

Lab Supervisor:

Yael K. V. Julia



Date Issued: B-28-C6 Revision Date: Jan. 05

Compressive Strength of Concrete Cylinder Test Specimens
ASTM C39 / C143 / C239 / C1064

ASTM C39 / C143 / C239 / C1064

Jones & DeMille Engineering
1535 South 100 West
Richfield, UT 84701
Phone: (435) 998-8266 Fax: (435) 966-8268

Project: Parvanti Elementary Addition

Concrete Supplier: Hales Sand & Gravel

Project Number: 0802-080

Client School DistCement Source: AshtgroveType: IN

Aggregate Source: Hales

Send Source: Ha'e

Mix ID Number:

Air Entraining.

Beg Mix: 0.5

Truck & Trailer No.

Concrete Temp. (F): 73 FAir Temp (°F) 68 FSize of Cylinders 4 x 6

Cylinders Cast: _____ 4

Aggregate Size

Yajnos Baccarelli

Air Correlation Factor

Conclusion

Slump: 5"

Alt: 6.2

Carl By

Tom L.

With Fiber

[illegible]Cylinders Broken By: Daniel Hawley

Lab Supervisor:

Comments: Set #2 Load #5